

LONGHORN ARMY AMMUNITION PLANT

KARNACK, TEXAS

ADMINISTRATIVE RECORD

VOLUME 1 of 1

1976

**Bate Stamp Numbers
000001 - 000032**

Prepared for:

**Department of the Army
Longhorn Army Ammunition Plant
Marshall, Texas 75671-1059**

1995

**LONGHORN ARMY AMMUNITION PLANT
KARNACK, TEXAS
ADMINISTRATIVE RECORD - CHRONOLOGICAL INDEX**

VOLUME 1 of 1

1976

**A. Title: Final Report - AEHA Water Quality Special Study
No. 24-0586-77
Group(s): 2 (Partial), 4
Site(s): LHAAP-18 & LHAAP-24 Burning Ground / Washout Pond & Evaporation Pond
LHAAP-35 Process Wastewater Sumps - Various
LHAAP-36 Explosive Waste Pads
Location: Longhorn Army Ammunition Plant, Marshall, Texas
Agency: U.S. Army Environmental Hygiene Agency, Aberdeen Proving Ground
Author(s): U.S. Army Environmental Hygiene Agency, Aberdeen Proving Ground
Recipient: Commander, USA Material Development And Readiness Command
Date: August 2 - 10, 1976
Bate Stamp: 000001 - 000032**

July 12, 1995

000001

WATER QUALITY SPECIAL STUDY NO. 24-0586-77
LONGHORN ARMY AMMUNITION PLANT
MARSHALL, TEXAS
2 - 10 AUGUST 1976



US ARMY
ENVIRONMENTAL HYGIENE AGENCY
ABERDEEN PROVING GROUND, MD 21010



HSE-EW/WP

000002

DEPARTMENT OF THE ARMY
U. S. ARMY ENVIRONMENTAL HYGIENE AGENCY
ABERDEEN PROVING GROUND, MARYLAND 21010

23 AUG 1977

WATER QUALITY SPECIAL STUDY NO. 24-0586-77
LONGHORN ARMY AMMUNITION PLANT
MARSHALL, TEXAS
2 - 10 AUGUST 1976

ABSTRACT

A water quality engineering study was conducted 2-10 August 1976 to characterize wastes in both the industrial waste sumps and the industrial waste pond to ascertain if the supernatant could be discharged directly to the surface drainage or would require treatment. The concentrations of barium, lead, total nitrogen and solids, the lack of mixing and the continuing chemical activity of the supernatant preclude its discharge to surface drainage. Findings, conclusions and recommendations cover operations at sumps and equipment cleanup areas. The analytical results and the visual review of surface water drainage throughout the installation indicate that present liquid waste management practices have no adverse effects upon the aquatic biota.

Water Quality Sp Study No. 24-0586-77, 2-10 Aug 76

CONTENTS

Paragraph	Page
1. AUTHORITY	1
2. REFERENCE	1
3. PURPOSE	1
4. GENERAL	2
a. Acknowledgements	2
b. Personnel Contacted	2
c. Abbreviations and Definitions	2
d. Background	2
e. Industrial Waste Sumps	4
f. Industrial Waste Pond	4
g. Water Supply and Treatment	4
(1) Source	4
(2) Potable Water Treatment	5
(3) Fire Water	5
h. Precipitation	5
5. PROCEDURES	5
a. Sampling	5
b. Sampling Points	5
c. Handling of Samples	5
d. Analyses	6
6. FINDINGS	6
a. General	6
b. Industrial Waste Sumps	6
(1) Analytical Results	6
(2) Observations	7
(3) Ditches	8
c. Drainage	8
(1) Burning Ground	8
(2) Pot Cleanup Area	8
d. Industrial Waste Pond	9
(1) Supernatant	9
(2) Sediments	10
(3) Evaporation	10
e. Receiving waters	10
(1) General	10
(2) North Bayou	10
(3) Central Bayou	10
(4) Harrison Bayou	10
f. Water Consumption	11

Water Quality Sp Study No. 24-0586-77, 2-10 Aug 76

Paragraph	Page
7. CONCLUSIONS	12
8. RECOMMENDATIONS	13
9. CONSULTATION AND ASSISTANCE	13

Appendix

A - Abbreviations and Definitions	A-1
B - Tables	B-1
Table 1 - Description of Samples and Sample Point Locations	B-2
Table 2 - Analytical Procedures	B-3
Table 3 - Stability of Liquid Samples as Indicated by Changes In pH	B-3
Table 4 - Analytical Results for Industrial waste Sump Supernatants	B-5
Table 5 - Summary of Results for Industrial waste Sump Supernatants	B-7
Table 6 - Analytical Results for Industrial waste Sump Sediments	B-8
Table 7 - Drainage from Burning Ground and Pot Cleanup Areas	B-9
Table 8 - Analytical Results of Industrial Waste Pond Supernatant	B-10
Table 9 - Analytical Results of Industrial Waste Pond Sediments	B-11
Table 10 - Characterization of Receiving Waters	B-12

000005



DEPARTMENT OF THE ARMY
U. S. ARMY ENVIRONMENTAL HYGIENE AGENCY
ABERDEEN PROVING GROUND, MARYLAND 21010

HSE-EW/WP

WATER QUALITY SPECIAL STUDY NO. 24-0586-77
LONGHORN ARMY AMMUNITION PLANT
MARSHALL, TEXAS
2 - 10 AUGUST 1976

1. AUTHORITY.

- a. AR 40-5, Health and Environment, 25 September 1974.
- b. AR 200-1, Environmental Protection and Enhancement, 7 December 1973 with two changes.
- c. Letter, DRSAR-ISE, US Army Armament Command, 18 February 1976, subject: USAEHA Mission Services FY 77, ARMCOM Environmental Engineering Requirements.

2. REFERENCE. USAEHA Water Quality Engineering Special Study No. 24-014-72/73, Longhorn Army Ammunition Plant, Marshall, Texas, 3-19 April 1972 (8 December 1972).

3. PURPOSE.

- a. This study was conducted at the request of ARMCOM (now ARRCOM) (Authority 1c). As consideration is being given to the discharge of the settled supernatant from an industrial waste evaporation basin to the surface drainage, the characterization of the waste is essential to determine extent of treatment required to meet NPDES permit requirements.

- b. Specific objectives developed during the entrance interview and tour of operations were:

- (1) Characterization of liquid and settled sludge in the industrial waste pond.
- (2) Characterization of liquid and settled sludges in sumps associated with manufacturing operations which are collected and discharged to the industrial waste pond.
- (3) Review of water consumption.

- c. Limitation. A previous study performed 3-19 April 1972 (reference 2) provided comprehensive coverage of waste discharges from the water treatment plant, sanitary sewage treatment plant, power plant, and laundry. As the recommendations drawn upon the findings made in this previous report are being augmented under MCA projects, repetition of past coverage was not deemed pertinent or necessary. Coverage of this study may be considered a supplement to areas not covered in reference 2.

Water Quality Sp Study No. 24-0586-77, 2-10 Aug 76

4. GENERAL.

a. Acknowledgements. The excellent cooperation received from both US Government and Thiokol Chemical Company personnel was appreciated during this study.

b. Personnel Contacted.

LTC Paul L. Greenberg, Commanding Officer
MAJ Charles R. Carson, Executive Officer
Mr. Don Maley, Chief Engineer, US Army
Mr. Robbie L. Wilson, Operations Review Officer, US Army
Mr. David T. Rayner, Facilities Design Supervisor, Thiokol Chemical Company
Mr. Herman Krackenberger, Quality Assurance Supervisor, Thiokol Chemical Company
Mr. C. W. Ford, Transportation, Thiokol Chemical Company
Mr. Max Morgan, Chemist, Thiokol Chemical Company

c. Abbreviations and Definitions. A glossary of technical terms and units, along with other appropriate abbreviations, is available in Appendix A. Abbreviations and units in this report are included therein.

d. Background.

(1) General. LAAP is GOCO installation under the jurisdiction of ARRCOM. Thiokol Chemical Corporation is the contractor operator of the plant. The installation's primary missions are the load, assembly and pack of pyrotechnic signals and the loading of rocket motors.

(2) Geography and Receiving Streams. LAAP is located 16 miles northeast of Marshall, Texas, on the southwest shore of Caddo Lake, a shallow lake with a surface area of approximately 40,000 acres (16,200 ha). LAAP's 3,523 acres (3452 ha) are drained toward Caddo Lake by three major streams (see Figure). The southern part of the installation is drained by Harrison Bayou, which originates off the installation and flows in a northeasterly direction. Discharges to this bayou consist of storm runoff. The northern and central areas of the installation are drained by two unnamed bayous. These will be referred to in this report as Northern and Central Bayou, respectively. Central Bayou originates on the installation as two branches flowing through the magazine area in a northeasterly direction, combining before draining into Caddo Lake. Discharges to the bayou consist of storm runoff and thus the bayou flows intermittently. Northern Bayou also originates on the installation initially flowing in an easterly and then northeasterly direction. Upon completion of MCA projects, presently under construction, this bayou will receive the plant's major discharges. These include once through cooling waters and the discharge from the sanitary sewage treatment plant.

000007

Quality Sp Study No. 24-0586-77, 2-10 Aug 76




FIGURE. MAP OF SAMPLING POINTS - LONGHORN ARMY AMMUNITION PLANT, TX.

Water Quality Sp Study No. 24-0586-77, 2-10 Aug 76

(3) **Terrestrial Vegetation.** Terrestrial vegetation includes deciduous and coniferous trees in wooded areas and lush dense grass elsewhere.

(4) **Soils.** Soils may be characterized as consolidated mixtures of sand, silt, and clay with very low permeability as demonstrated by tests performed on soils at LAAP. Grain size distribution was 46 to 48 percent sand, 35 to 36 percent silt, and 16 to 19 percent clay. On two samples the permeability ranged between 6×10^{-5} and 1×10^{-6} cm/sec. These quaternary deposits ranged from 5.0 ft to 25.0 ft in depth. The low permeability of the soils was further demonstrated by the ponding of waters from cooling water discharges, ponding of dried up streams, and the existence of Caddo Lake. While the general region is reported to serve as the region of surface water recharging to the Cypress Aquifer through the outcropping of more permeable soils, no such areas were encountered on the installation.

(5) **Population.** The predicted population of LAAP at mobilization levels of operation is 4779. The present population level is 679 persons. As no housing is provided on the installation, population levels represent the work force. The septic tank fields serve approximately 12 percent of the working force and the sanitary sewage treatment plant serves the balance.

(6) **Plant Operation:** The plant's operations fluctuate directly with the demand for pyrotechnic ammunition and rocket motors. At the time of the study, the plant was basically operating on a one shift, 8-hour workday, 5-day workweek schedule. Certain operations, however, utilize partial night shifts to maintain necessary support and production continuity.

e. **Industrial Waste Sumps.** Since most production operations consist of component assembly, rather than manufacturing, only small volumes of production related wastewaters are generated, primarily by housekeeping practices. These wastewaters are considered contaminated by explosives or illuminants and are discharged to sumps, where particulates are allowed to settle out. These sumps are pumped out into tank trucks periodically, and transported to an evaporating pond located at the explosive burning grounds. There are approximately 150 sumps.

f. **Industrial Waste Pond.** An industrial waste pond is used to contain solids and liquid wastes from the industrial waste sumps. Liquid and solid wastes from the rocket motor washout facility immediately to the north are also discharged to this pond. The pond is approximately 300 ft X 300 ft X 14 ft deep (91.44 m X 91.44 m X 4.27 m) covering two acres (0.81 ha).

g. **Water Supply and Treatment.**

(1) **Source.** LAAP obtains its water from the Black Cypress Bayou (see Figure) which connects Lake of the Pines with Caddo Lake. The raw water is pumped from the bayou through a screened intake into a 2.8 MG (10,598 m³)

Water Quality Sp Study No. 24-0586-77, 2-10 Aug 76

capacity storage tank located adjacent to the WTP. The large pumping capacity [2- 7,800 gpm (29.52 m³ per second), 1- 2,000 gpm (7.57 m³ per minute)] was originally installed to meet the requirements for TNT manufacture. LAAP no longer manufactures TNT and all the related facilities have been moved from the installation. Flow measurements are determined by timing pump operation.

(2) Potable Water Treatment. From the 2.3 MG (10,593 m³) tank, the raw water flows by gravity through a mixing chamber (where lime, alum, and chlorine are added) into one of two upflow clarifiers, which are used alternately. The water then flows through rapid sand filters into the 375,000 gallon (1419 m³) capacity clear well, where it is pumped into the distribution system. Sodium hexametaphosphate is added manually at the sand filters for corrosion control. After filtration, the water is chlorinated to maintain a 0.5 mg/l total chlorine residual in the system, and lime is added for pH control. The plant has a 2.3 MGD (8,706 m³ per day) capacity. Flow measurements are computed by timing pump operations. The potable water source supplies drinking, fire, cooling and wash down waters.

(3) Fire water. Fire water is raw water pumped from the 2.3 MG (10,593 m³) tank. Flow measurements are computed by difference of raw and treated waters. This water serves as the principal source for fire and cooling.

n. Precipitation. The average annual rainfall is 45 in (114.3 cm), the mean annual lake evaporation is 54 in (137.2 cm) and the average annual runoff is 15 in (38.1 cm).

5. PROCEDURES.

a. Sampling. Grab sampling was used exclusively. The fact that wastes in the sumps and pond represented collections over long periods, from a week to years, negated the requirement for time or flow composited sampling. Liquids were dipped from the top 12 in (30.48 cm). At the industrial waste pond three grab samples were collected along the diagonal and combined to form a single composite sample. Three composite samples were collected in this manner. Sediments were collected using a 1-1/2 in (3.81 cm) diameter plastic pipe which was inserted into the bottom sediments and withdrawn as with a pipette.

b. Sampling Points. The locations of sample points are indicated on the figure of the map of the installation. The sample number, type and description of the location are provided in Table 1, Appendix B.

c. Handling of Samples. Samples were divided and preserved by USAEHA personnel in accordance with the following schedule:

Water Quality Sp Study No. 24-0586-77, 2-10 Aug 76

- (1) Metals were preserved with 1.5 to 2.0 ml nitric acid per 8 oz (237 ml) bottle resulting in pH 2 or less.
- (2) Nutrients and TOC were preserved with 0.2 ml sulfuric acid per 8 oz (237 ml) bottle.
- (3) Phenols were preserved with phosphoric acid and copper sulfate to pH 3.0 or less.
- (4) General analyses samples were not preserved.
- (5) Oil and grease were preserved with 1 ml sulfuric acid resulting in pH 2 or less.

Samples were packed by USAEHA personnel for shipment to USAEHA for analysis. LAAP personnel handled shipment of samples.

d. Analyses. The parameters for analysis were chosen from a review of compounds used in the manufacture of military pyrotechnics, installation purchase orders, USEPA NPDES permits and key plant personnel assessments. The analyses were performed at the USAEHA by Agency personnel in accordance with the procedures indicated in Table 2, Appendix B.

6. FINDINGS.

a. General. No aluminum, cobalt, titanium, tungsten or zirconium were found in detectable amounts in any liquid wastes, streams or raw water. The pH of liquid samples changed for many samples between the time they were collected and the time of analysis at this Agency as noted in Table 3, Appendix B. A change in more than one pH unit indicates a lack of chemical stability of the waste and is so noted in the table.

b. Industrial Waste Sumps.

(1) Analytical Results. The analytical results for the liquid supernatants from the sumps at production buildings are provided in Table 4, Appendix B, with a summary of high, low and average values provided in Table 5, Appendix B. The analytical results for sediments are provided in Table 6, Appendix B. While the range in parameters for the 10 sumps sampled is broad with concentrations frequently below the detectable limit, in every instance there are one or more parameters which preclude the free discharge to surface drainage. The sediments are rich in all parameters tested with the exception of mercury for which all analyses were below the detectable limit. While the concentration is relatively high in the supernatant for sample 10, none was found in the sediment.

Water Quality Sp Study No. 24-0586-77, 2-10 Aug 76

(2) Observations.

(a) General. At the time of the study the installation was experiencing mechanical problems with the pump on the tank truck used to collect supernatant liquids and sediments from the sumps. Within a week the pump was repaired and routine pumping recommenced. If a problem exists with the present routine, it lies in the coverage of inactive areas where slow leaks and storm runoff fill up the sumps. The installation does not maintain a list of all sumps nor records on inspection or dates each is pumped. The findings at sumps illustrates the need for extending the present routine of pumping sumps at active production sites to inspection of inactive sites and all sites after a rainfall.

(b) SP 05. The covered sump was full. Mosquito larvae were observed living in the supernatant. The sediment collected from the sump could not be safely shipped to the Agency because it was producing gas. Within a few hours the plastic cube container containing the sample had expanded to a point of bursting. Hydrochloric acid was added to a portion of the sample to drive the reaction to completion requiring twice the volume of acid to the volume of sludge. As time did not permit treatment of the entire sample, the sample was discarded. The covers to the sump did not have a vent to allow the discharge of gases generated from the reaction of waste ingredients.

(c) SP 06. The covered sump was full. A skim of oil was observed on the sediment sample.

(d) SP 07. The covered sump was full. No oil was observed.

(e) SP 08. The sump had no cover and was nearly empty. No sediment was found. While the sump was nearly empty the analyses indicated a strong industrial waste.

(f) SP 09. The sump had no cover, was almost empty and contained no solids. The COD, barium and chromium concentrations were appreciable.

(g) SP 10. The sump had no cover and was almost empty. Both the supernatant and sediment were strong industrial wastes. The magnesium content was the highest of any sump sediment analyzed.

(h) SP 11. The covered sump was full. Some oil and grease were observed on the surface. A frog was observed living in the sump. A trichlor odor was noticed while collecting samples.

(i) SP 12. The sump was either overflowing from waste discharges or surface drainage was flooding the sump. The sediment had an organic decay odor. The wood cover was covered with sod. Minnows were observed living in pooled water. With a pH 6.0 and a relatively weak wastewater, the waters might be expected to support life. However, the change in pH during shipment of the sample indicates that the sump wastes are not stable.

Water Quality Sp Study No. 24-0586-77, 2-10 Aug 76

(j) SP 13. As the wood cover was jammed from swelling caused in part by a heavy layer of vegetation, it was not possible to remove it. Consequently no samples were collected.

(k) SP 14. The sump had no cover and was half full of a 50-50 mixture of supernatant and sediment. While the supernatant did not carry the normal array of metals and was relatively stable, it did contain high concentrations of COD, $\text{NO}_2/\text{NO}_3\text{-N}$ and barium. The sediment sample collected could not be snipped for the same reason as sample 05, [see paragraph 0b(2)(b)].

(l) SP P-1. The uncovered sump was full. The effluent bypass pipe was plugged preventing the 12 inch (30.5 cm) head of supernatant from discharging to the surface drainage. Outside of FDS and low pH the supernatant was relatively weak. The sludge was a bright red with a low solids content.

(3) Ditches. Ditches were inspected downstream of all sumps. In all cases lush vegetative growth of a wide variety of plants grew in and along them. Where ditches carried water, a variety of algae, plants, fish and invertebrate insect life were prevalent.

c. Drainage.

(1) Burning Ground. Drainage from the burning ground was collected from stagnant pools along the main drainage ditch to ascertain the extent of potential pollution from this area. The analytical results provided in Table 7, Appendix B, indicate a barium concentration as the only parameter of potential concern. As barium would be diluted in general runoff to well below 1.0 mg/l which is a recognized standard for the States of Illinois and Virginia, (no Texas Standard), there is no indication of a problem area.

(2) Pot Cleanup Area. Several cleanup areas were observed where pots and vessels, used in conveying and mixing various substances, are cleaned by flushing in open areas. The flushings are then discharged directly to surface drainage ditches. The analytical results for sample 28, Table 7, Appendix B, collected from one operating location indicate a very acid waste with high TSS. While the COD is not high, 60 mg/l, the theoretical COD based upon the DOC value is only 15. The difference between measured and computed values can be inorganic oxygen demand. However, the source or cause of the difference is not apparent from the analysis. As there is little difference in the source of these discharges from those collected in the industrial sumps, the array of parameters during cleaning operations and likely their concentrations would be very similar. As such, these discharges do constitute an industrial waste which should be collected and contained in a sump and similarly disposed of.

Water Quality Sp Study No. 24-0586-77, 2-10 Aug 76

d. Industrial Waste Pond.

(1) Supernatant.

(a) The analytical results for the industrial waste pond supernatant are provided in Table 8, Appendix B. The supernatant has three characteristics which prevent its discharge to surface drainage--high concentrations of substances, lack of mixing and continuing chemical activity.

(b) The concentrations of TS and TDS are high as are total nitrogen, chloride, strontium and barium. The average TOC correlates very closely with COD, 46.3 mg/l for a theoretical COD based on TOC as against 45 mg/l for measured COD. This indicates there is no inorganic oxygen demand. While the average lead concentration (0.09 mg/l) is within the range of established State water quality standards, 0.05 mg/l for Virginia and 0.1 mg/l for Illinois (Texas has no standard), the single high value (0.27 mg/l) would be reason to prevent discharge to surface streams.

(c) While the concentrations of most parameters are well within a 10 percent analytical variation, the ranges of iron, lead, tin and zinc indicate that complete mixing is not accomplished and as a result chemical reactions with bottom sediments can be expected. It would be difficult if not impossible to say where stabilization of supernatant occurs such that the supernatant could be safely drawn off.

(d) There is a complex array of chemical reactions occurring among supernatant parameters which result in precipitation of some parameters and between the supernatant and sediments which solubilize others. The concentration of zinc in sump supernatant samples ranged between 0.112 and 2.12 mg/l, while in the pond supernatant, the range fell to between 0.036 and 0.067 mg/l. Similar reductions are seen for chromium, iron, manganese and silicon. The observed gaseous eruptions in the vicinity of the truck dumping station can be attributed to hydrogen from the reaction of magnesium metal with a slightly acid supernatant. The generation of hydrogen, associated with the storage of moist magnesium, is a recognized hazard by Thiokol Chemical Corporation personnel. The lack of chemical stability is further demonstrated with a drop in pH from 6.5 to 4.1 during storage and transport of the supernatant samples (see Table 3, Appendix B).

(e) The lack of normal plant and animal life in the pond attests to the toxicity of the wastes. No plant life was observed in the pond. While turtles were observed swimming in the pond, the carcasses of two turtles were found at the edge of the pond. Turtles are extremely mobile and their occurrence in such a limited environment can not be construed as a lack of toxicity. They can and apparently do survive in such ponds primarily because they breathe air and do not ingest large quantities of the pond contents relative to their body weight.

Water Quality Sp Study No. 24-0586-77, 2-10 Aug 76

(2) Sediments. The analytical results of industrial waste pond sediments are provided in Table 9, Appendix B. The variations in parameter concentrations are much greater than with the pond supernatant. The point G18 which was furthest from the influent point has the lowest concentrations of parameters and percent solids. In general, the higher concentration of parameters occurs in the vicinity of the influent. The increase in solids from 2.75 percent for sump sediments to 12.05 percent for pond sediments indicates that sediments are being concentrated in the pond.

(3) Evaporation. The need for considering discharge of the supernatant is appreciated for the net evaporation is only 9 in per year. The gross evaporation of 54 in less 45 in per year rainfall leaves only 9 in evaporation.

e. Receiving Waters.

(1) General. The characteristics of receiving waters are presented in Table 10, Appendix B, along with controls from Caddo Lake and the raw and treated tap water. The raw water drawn from Black Cypress Bayou, when treated, increases in TS and TDS from the addition of lime and alum. Comparisons of raw and treated waters analyzed under the drinking water surveillance program indicated that there was no change in water characteristics other than slight increases in TD, TDS, calcium and sulfates in the treated waters.

(2) North Bayou. The increases in parameters in the North Bayou over the treated water supply are slight and are traceable to discharges of boiler blowdown, water softening operations, water treatment plant sludge and filter backwashes and sewage treatment plant effluent. Completion of projects presently under construction to improve the treatment of these waste waters will bring the concentrations of parameters down to a point which will make the waters in the North Bayou indiscernible from the control waters. At the present time the concentrations of metals are generally below those of Harrison Bayou as it flows onto the installation. The abundant diverse plant life along the bayou and the fish observed in pooled stretches attest to the quality of North Bayou waters.

(3) Central Bayou. The quality of water discharging to Caddo Lake is as good or better than the controls. This bayou drains the area where extensive use is made of septic tanks with filter beds for the treatment of sanitary sewage. The pH stability and low metals confirm observations that no industrial wastes are being discharged to this ditch.

(4) Harrison Bayou. With the exception of conductivity, TS, TDS, COD, TP, chloride, iron and silicon, the quality of the waters in Harrison Bayou is as good or better as they leave the installation than when they enter it. A comparison of sample 26 with the controls indicates no significant or adverse effects from the drainage from the burning ground area. An abundant variety of animal and plant life prevails everywhere along this bayou.

Water Quality Sp Study No. 24-0586-77, 2-10 Aug 76

f. Water Consumption. Water production is measured by timing pump operations. The flow meters provided were designed to measure the quantities used in support of TNT production, something in the order of 30 MGD. The present consumption rate lies below the minimum measurable limits of the meters. The average daily recorded water pumped is:

Fire water	99 TGD
Potable	504 TGD
Total Daily	<u>603 TGD</u>

Applying average loading factors the accountable water usage is as follows:

Government and Thiokol Personnel

679 workers X 30 gpcd/1000 =	20.4 TGD
------------------------------	----------

Construction Workers

49 workers X 30 gpcd/1000 =	1.5 TGD
-----------------------------	---------

Steam $\frac{2,980 \text{ gallons per month}}{30 \text{ days per month (1000)}} =$	9.3 TGD
--	---------

Boiler Plant Blowdowns

300 GPH X 12 Hours/1000 =	3.6 TGD
---------------------------	---------

Backwash to Filters at Water Treatment Plant

$\frac{650,000 \text{ gallons per month}}{30 \text{ days per month (1000)}} =$	21.7 TGD
--	----------

Production Wash Down to Sumps =	<u>10 TGD</u>
---------------------------------	---------------

Total Accountable Water Used =	156.5 TGD
--------------------------------	-----------

The unaccountable water is by difference:

Pumped	603 TGD
Accountable	<u>156 TGD</u>
Unaccountable	447 TGD

The sanitary sewage averaged 40 TGD according to the plant operator. Assuming 70 percent of water pumped reaches the plant, the water consumed for personnel, shops and power house blowdown should approach 40 TGD/0.70 or 57.1 TGD. The estimated sum of personnel use (21.9 TGD) and the boiler plant blowdown (3.6 TGD) is 25.5 TGD which indicates a higher percapita usage than

Water Quality Sp Study-No. 24-0586-77, 2-10 Aug 76

assumed or unidentified uses. While water used for compressor cooling, air conditioning, car washing, wash down, cafeterias, and leaks is not included, it is difficult to imagine values which would account for 447 TGD. The lack of flow meters throughout the system prevents any accurate estimation or control of uses or losses.

7. CONCLUSIONS.

a. The present sump pumping program does not include periodic inspection of inactive sites or inspection of all sites after a rainfall.

b. Accessibility to sumps is limited by poor maintenance of covers.

c. The covers to sumps are not designed to prevent the collection of hydrogen or other gases produced by the chemical reaction of sump contents.

d. Ditches and receiving streams have not been damaged by any possible inadvertant sump overflow or drainage from pot cleaning or burning ground activity [see paragraph 6b(3) and 6e].

e. The high concentrations of barium, total nitrogen, lead and total solids render the quality of the industrial waste pond supernatant unsatisfactory for discharge to streams.

f. The contents of the pond are chemically active with no apparant point where waste supernatant is sufficiently stabilized to permit discharge to streams.

g. The Industrial Waste Pond functions to precipitate suspended and dissolved solids and concentrate sediments from sump wastes.

h. Waste discharges from pot and vessel cleaning operations are not collected, contained or treated as sump wastes.

i. The lack of a wide diversity of biological life in the Industrial Waste Pond is indicative of the toxicity of its contents.

j. There is no indication the waters of the North, Central or Harrison Bayous are or have been adversely affected by production activities.

k. No operable flow measurement equipment is provided on treated or fire water lines.

l. Water consumption is higher than can be justified by rough estimates.

Water Quality Sp Study No. 24-0586-77, 2-10 Aug 76

8. RECOMMENDATIONS.

a. Treat Industrial Waste Pond supernatant to remove waste parameters before discharging to the streams, see paragraph 6d.

b. Extend sump pumping program to periodic inspection and pumping of inactive sites and all sites after rainfall [see paragraph 6b(2)(d)].

c. Improve maintenance of sumps and sump covers [see paragraph 6b(2)(j)].

d. Design all sump covers to prevent the collection of hydrogen or other gases [see paragraph 6b(2)(b)].

e. Collect, contain and treat wastes discharged from pot and vessel cleaning operations [see paragraph 6c(2)].

f. Install adequate flow measurement equipment on treated and fire water lines to control and identify consumption, see paragraph 6f.

9. CONSULTATION AND ASSISTANCE.

a. This Agency will provide further consultation and assistance in the implementation of the recommendations made in this report upon request. Requests for such assistance should be directed through appropriate channels to Commander, USA Health Services Command, ATTN: HSPA-H, Ft Sam Houston, TX 78234, in accordance with paragraph 1-5, AR 40-5.

b. Technical consultation can be obtained informally by contacting the Chief, Water Quality Engineering Division (AUTOVON 584-3845/3554).

000018

Water Quality Sp Study No. 24-0586-77, 2-10 Aug 76

Robert O. Mather

ROBERT O. MATHERN, P.E.
Sanitary Engineer
Water Quality Engineering Division

APPROVED:

J. Don Gensler

J. DON GENSLER

LTC, MSC

Chief, Water Quality Engineering Division

John P. Piercy

JOHN P. PIERCY, P.E.

COL, MSC

Director, Environmental Quality

Water Quality Sp Study No. 24-0586-77, 2-10 Aug 76

APPENDIX A

ABBREVIATIONS AND DEFINITIONS

Al	aluminum
ARMCOM	US Army Armament Command
ARRCOM	US Army Armament Materiel Readiness Command (This organization was formerly known as ARMCOM)
B	boron
Ba	barium
Ca	calcium
CaCO ₃	calcium carbonate
Cd	cadmium
Cl	chloride
cm	centimeter
cm/sec	centimeters per second
COD	chemical oxygen demand
Co	cobalt
Cr	chromium
Cu	copper
F	fluoride
ft	feet
Fe	iron
GOCO	government owned contractor operated
GPD	gallons per day
gpcd	gallons per capita per day
GPH	gallons per hour
gpm	gallons per minute
H	hydrogen
h	hours
ha	hectares
Hg	mercury
HNO ₃	nitric acid
H ₂ SO ₄	sulfuric acid
in	inches
K	potassium
kg	kilogram
km	kilometer
LAAP	Longhorn Army Ammunition Plant
m	meter
m ³	cubic meters
Mg	magnesium
MG	million gallons
MGD	million gallons per day
mg/l	milligrams per liter
ml	milliliter

Water Quality Sp Study No. 24-0586-77, 2-10 Aug 76

Mn	manganese
Mo	Molybdenum
N	nitrogen
Na	sodium
ND	Not detectable
NH ₃ -N	ammonia nitrogen
NO ₂ /NO ₃ -N	nitrite and nitrate nitrogen
NPDES	National Pollutant Discharge Elimination System
O	oxygen
O ₂	oxygen gas
P	phosphorus
Pb	lead
pH	Negative logarithm (base 10) of hydrogen ion (H ⁺) concentration
ppm	parts per million parts by weight
S	sulfur
Sb	tin
Si	silicon
SiO ₂	silicate
SO ₄	sulfate
SP	sample point
Sr	strontium
STP	sewage treatment plant
TDS	total dissolved solids
TGD	thousand gallons per day
TKN	total Kjeldahl nitrogen expressed as N
TOC	total organic carbon
TP	total phosphorus
TS	total solids
TSS	total suspended solids
Ti	titanium
µmho/cm	micromhos per centimeter
USAEHA	US Army Environmental Hygiene Agency
W	tungsten
WTP	Water Treatment Plant
Zn	zinc
Zr	zirconium

Water Quality Sp Study No. 24-0586-77, 2-10 Aug 76

APPENDIX B

Laboratory analyses as presented in Tables 4 and 6 through 10 were performed by personnel of the Environmental Chemistry Division of USAEHA.



PETER FIANU
Chemist
Water and Waste Chemistry Branch

Water Quality Sp Study No. 24-0586-77, 2-10 Aug 76

APPENDIX B

TABLE 1. DESCRIPTION OF SAMPLES AND SAMPLE POINT LOCATIONS

Sample No.	Type		Location
	Liquid	Sediment	
05	X		Sump, Bldg P-1
06	X		Sump, Bldg P-3 (w/air cleaner device)
07	X		Sump, Bldg P-3
08	X		Sump, Bldg P-11 (w/air cleaner device)
09	X		Sump, Bldg B-10
10	X		Sump, Bldg B-7
11	X		Sump, Bldg 45-E, West Sump
12	X		Sump, Bldg 45-E, Central Sump
13	X		Sump, Bldg 45-E, East Sump
14	X		Sump, Bldg 34-Y, Igniter Area
15	X		Industrial Waste Pond, Composite of 3 grab samples
16	X		Industrial Waste Pond, Composite of 3 grab samples
17	X		Industrial Waste Pond, Composite of 3 grab samples
22	X		Raw Water, Tap from Water Treatment Plant
23	X		Caddo Lake @ Starr Ranch, background
24	X		Harrison Bayou at county road off Rt 134
25	X		Central Bayou, east of Igniter Area
26	X		Harrison Bayou, east of Static Test Area
27	X		North of Bayou at 59th Street
28	X		Ditch Sample adjacent to pot-cleanup across from Bldg B-11
P-1	X		Sump, Bldg 33G
P-2	X		Stagnant Stream below burning ground area
P-3	X		Cold water tap at Quality Assurance Lab
P-4	X		Stream to North Bayou at Karnack Road
G05		X	Same location as 05
G06		X	Same location as 06
G07		X	Same location as 07
G08		X	Same location as 08
G09		X	Same location as 09
G10		X	Same location as 10
G11		X	Same location as 11
G12		X	Same location as 12
G14		X	Same location as 14
G18		X	Industrial Waste Pond
G19		X	Industrial Waste Pond
G20		X	Industrial Waste Pond
G21		X	Industrial Waste Pond
GP-1		X	Same location as P-1

Water Quality Sp. Study No. 34-0586-77, 2-10 Aug 76

TABLE 2. ANALYTICAL PROCEDURES

Parameter	Symbol	Expressed As	Units	Detection Limit	Procedure
pH	pH		Units 0-14		Standard Methods ¹ , 144 A. Glass Electrode Method Pg 276 (Tape for Field Measurements)
Acidity		CaCO ₃	mg/l		Standard Methods ¹ , 101, Acidity, pg 50
Alkalinity		CaCO ₃	mg/l		Standard Methods ¹ , 102, Alkalinity, pg 52
Total Organic Carbon	TOC	C	mg/l	1.0	Standard Methods ¹ , 138A Combustion-Infrared Method (Tentative), page 257. Samples were acidified and homogenized prior to analysis.
Ammonia	NH ₃ -N	N	mg/l	.03	(a) Concentration Range 0.03-1.0 mg/l; Selective ion Electrode Method, Orion Research, Instruction Manual, Ammonia Electrode Model 95-10, 1972. (b) Concentration Range 1.0-100 mg/l; Preliminary Separation by Microdiffusion ³ and Selective Ion Electrode Determination, Orion Research Institution Manual, Ammonia Electrode Model 95-10, 1972. ²
Nitrite/Nitrate	NO ₂ /NO ₃ -N	N	mg/l	.04	Technicon Auto Analyzer ⁴ , Industrial Method 33-69W, preceded by sample treatment with Aluminum Hydroxide Suspension, as in Standard Methods ¹ , pg 235.
Total Kjeldahl Nitrogen	TKN	N	mg/l	.10	Technicon Auto Analyzer ⁴ , Industrial Method 29-69A. Samples were acidified and homogenized prior to analyses.
Total Solids	TS	Solids	mg/l		Data obtained by summing values obtained from Standard Methods ¹ , 224C, Total Suspended Matter, pg 537; and Standard Methods ¹ , 224E, Dissolved Matter, pg 539
Total Dissolved Solids	TDS	Solids	mg/l		Standard Methods ¹ , 224E, Dissolved Matter, pg 539. Evaporated filtrate from Standard Methods ¹ , 224C, Total Suspended Matter, pg 537. Filtrate of samples with nitrobody contamination was oven dried over sand to prevent possible explosion. Samples with high dissolved solids content were dried at 180°C as in Standard Methods ¹ , 148, Residue, pg 286-288.
Total Suspended Solids	TSS	Solids	mg/l	3	Standard Methods ¹ , 224C, Total Suspended Matter, 103-105°C, pg 537
Oil and Grease	Oil and Grease		mg/l	10	Standard Methods ¹ , 137, Oil and Grease, pg 254 for relatively clean samples, Standard Methods ¹ , 209A, Soxhlet Extraction Method, pg 409 for samples with gross material contamination.
Total Phosphorus	TP	P	mg/l		Technicon Auto Analyzer ⁴ , Industrial Method 94-70W, preceded by sample digestion as in Standard Methods ¹ , 223 C, Preliminary Digestion Steps for Total Phosphorus III, pg 526.
Sulfate	SO ₄	SO ₄	mg/l		Standard Methods ¹ , 156 C, Turbidimetric Method pg 334
Chloride	Cl	Cl	mg/l		Standard Methods ¹ , 112 B, Mercuric Nitrate Method, pg 96. Used Hach diphenylcarbazone indicator-buffer powder pillows.
Fluoride	F	F	mg/l		Technicon Auto-Analyzer ⁴ , Industrial Method 129-71W/reliminary

see footnotes 1 2 3 4 on page B-4

TABLE 2. ANALYTICAL PROCEDURES (Continued)

Parameter	Symbol	Expressed As	Units	Detection Limit	Procedure
Chemical Oxygen Demand	COD	O ₂	mg/l	5	Standard Methods ¹ , 220 Oxygen Demand (Chemical) pg. 495
Conductivity		G	umho/cm		Standard Methods ¹ , 154, Specific Conductance, pg 323
Volatile Suspended Solids	VSS	Solids	mg/l		Standard Methods ¹ , 224 D, Volatile and Fixed Suspended Matter, pg 538
Phenols			mg/l	.01	Technicon Auto-Analyzer ⁴ , Industrial Method 27-71W/Preliminary
Boron	B	B	mg/l	.05	Automated Fluorometric Method for Determination of Boron in Waters, Detergents and Sewage Effluents ⁵ , Water Research, Vol 6, pg 1475.
Aluminum	Al	Al	mg/l	1.0	"Methods for Chemical Analysis of Water and Wastes, 1971 ⁶ Metals (Atomic Absorption Methods) pg H3, Preliminary Treatment of Samples, Para 4.1.3 pg 88.
Barium	Ba	Ba		.3	
Calcium	Ca	Ca		.1	
Cadmium	Cd	Cd		.005	
Cobalt	Co	Co		.2	
Copper	Cu	Cu		.025	
Chromium	Cr	Cr		.025	
Iron	Fe	Fe		.1	
Mercury	Hg	Hg		.0002	
Potassium	K	K		.5	
Magnesium	Mg	Mg		.5	
Manganese	Mn	Mn		.03	
Molybdenum	Mo	Mo		.5	
Lead	Pb	Pb		.1	
Tin	Sb	Sb		.5	
Silicon	Si	SiO ₂		2.0	
Strontium	Sr	Sr		.1	
Titanium	Ti	Ti		1.0	
Tungsten	W	W		10	
Zinc	Zn	Zn		.015	
Zirconium	Zr	Zr		10	

¹APHA, AWWA, WPCF, Standard Methods for the Examination of Water and Wastewater, 13th edition, 1971, American Public Health Association, New York, NY, 1971

²Orion Research Incorporated, Cambridge, Mass

³USNEHA, Environmental Chemistry Division, "Ammonia Determination by a Micro-Diffusion Method", Aberdeen Proving Ground, MD

⁴Technicon Corporation, "Technicon Auto-Analyzer Methodology", Industrial Methods, Technicon Instruments Corporation, Tarrytown, NY

⁵Canada Centre for Inland Waters, Dept of the Environment, Water Quality Division, "Automated Fluorometric Method for Determination of Boron in Waters, Detergents and Sewage Effluents", Water Research, Vol 6, pg 1475

⁶EPA, "Methods for Chemical Analysis of Water and Wastes, 1971," Environmental Protection Agency, National Environmental Research Center, Analytical Quality Control Laboratory, Cincinnati, Ohio 45268

000024

000025

Water Quality Sp Study No. 24-0586-77, 2-10 Aug 76

TABLE 3. STABILITY OF LIQUID SAMPLES AS INDICATED BY CHANGES IN pH.

Sample No.	pH Tape At Sample Point	pH Meter at Agency	Stability	
			High	Low
05	6.5	3.8		X
06	5.5	7.0		X
07	6.0	6.8	X	
08	7.0	7.1	X	
09	7.0	4.4		X
10	8.0	9.6		X
11	6.0	2.7		X
12	6.0	3.9		X
14	8.0	7.1	X	
15	6.5	4.0		X
16	6.5	4.1		X
17	6.5	4.1		X
22	6.4	6.5	X	
23		6.7		
24	6.2	6.9	X	
25	6.0	6.6	X	
26	6.0	3.1		X
27	6.0	3.3		X
28	6.0	2.6		X
P-1	3.0	2.5	X	
P-2	7.0	6.8	X	
P-3		6.8		
P-4	6.0	6.3	X	

Water Quality Sp Study No. 24-0586-77, 2-10 Aug 76

TABLE 4. ANALYTICAL RESULTS FOR INDUSTRIAL WASTE SUMP SUPERNATANTS

Parameter	Sump Samples*											P-1
	05	06	07	08	09	10	11	12	13	14		
pH	3.8	7.0	6.8	7.1	4.4	9.6	2.7	3.9		7.1		2.5
Alkalinity	2	4.3	37	358	0	198	0	2		189		0
Acidity	22	12	12	28	17	0	147	36		16		287
Conductivity	333	278	4440	999	244	6882	1221	366		1221		2220
TS	369	1987	4849	1133	241	11962	157	219		1135		684
TDS	356	1981	4843	1055	227	5950	133	191		1119		666
TSS	13	6	6	76	14	6012	24	28		16		18
VSS	4	1	3	54	13	1707	16	19		6		10
COD	29	23	20	166	121	4158	59	51		358		41
TOC	6	6	9	121	13	76	6	7		109		11
Oil & Grease				12.6	30.6	83.7						
Phenols	.01	.48	.40	.06	.01	.50	ND	ND		.14		.11
NH ₃ -N	.88	.10	.25	.08	.11	11.3	ND	.10		21		.15
TKN	1.3	3.0	3.0	4.3	1.2	19.5	0.55	0.31		32		1.1
NO ₂ /NO ₃ -N	.10	290	490	ND	1.3	920	ND	ND		83		ND
TP	ND	ND	.05	ND	.09	.23	ND	1.4		.06		ND
Cl	260	29	28	30	65	825	170	50		500		285
F	ND	ND	.11	ND	ND	ND	ND	ND		ND		ND
SO ₄	34	ND	2	12	12	280	10	80		1		115
Al	ND	ND	ND	ND	ND	ND	ND	ND		ND		ND
B	.08	ND	ND	.09	.05	ND	ND	ND		ND		ND
Ba	2.77	458	993	7.34	8.23	436	1.97	.33		93		ND
Ca	15.3	16.9	16.5	20.9	4.4	13.1	13.3	19.6		5.6		69.4
Cd	.005	.018	.029	.010	.011	.021	.010	.006		.008		.017
Co	ND	ND	ND	ND	ND	ND	ND	ND		ND		ND
Cu	.027	ND	.048	.029	ND	.060	.028	ND		ND		ND
Cr	ND	ND	.034	.034	1.143	ND	ND	ND		ND		ND
Fe	.24	ND	.30	1.31	.49	2.16	.33	.68		ND		12.1
Hg	.00038	ND	.00045	ND	ND	.18	ND	.0005		ND		ND
K	3.96	69.4	85.8	293	2.60	8.39	0.90	3.30		5.79		3.79
Mg	12.49	1.89	3.15	2.40	7.42	165.7	1.35	2.17		14.74		3.13
Mn	ND	ND	ND	ND	ND	ND	ND	ND		ND		ND
Mo	ND	.042	.077	3.76	ND	.075	.032	.244		ND		.619
Na	ND	ND	.12	1.41	ND	ND	ND	ND		ND		.26
Pb	ND	ND	.94	.58	ND	ND	ND	ND		ND		ND
Sb	ND	ND	ND	ND	ND	ND	ND	ND		ND		ND
Si	9.6	14.4	10.9	14.1	2.6	23.8	5.3	13.9		2.8		12.0
Sr	.210	224	660	.318	.106	1.113	ND	.115		160		.355
Ti	ND	ND	ND	ND	ND	ND	ND	ND		ND		ND
W	ND	ND	ND	ND	ND	ND	ND	ND		ND		ND
Zn	.224	.767	.376	.332	.246	.614	.118	.639		.112		2.12
Zr	ND	ND	ND	ND	ND	ND	ND	ND		ND		ND

* All values expressed in mg/l except pH in units and conductivity in umho/cm

Water Quality Sp Study No. 24-0586-77, 2-10 Aug 76

TABLE 5. SUMMARY OF RESULTS FOR INDUSTRIAL WASTE SUMP SUPERNATANTS

Parameter*	High	Low	Average
pH	9.6	2.5	
Alkalinity	358	0	83
Acidity	147	0	58
Conductivity	6882	278	1820
TS	11962	157	2274
TDS	5950	133	1652
TSS	6012	6	621
VSS	1707	1	183
COD	4158	20	503
IOC	121	6	36
Oil & Grease	83.7		
Phenols	.50	ND	.17
NH ₃ -N	21	ND	3.40
TKN	32	1.1	6.53
NO ₂ /NO ₃ -N	920	ND	178
TP	1.4	ND	.18
Cl	825	28	224
F	.11	ND	.01
SO ₄	280	ND	55
Al	ND	ND	ND
B	.09	ND	.02
Ba	458	ND	200
Ca	69.4	5.6	19.5
Cd	.029	.005	.014
Co	ND	ND	ND
Cu	.060	ND	.192
Cr	1.143	ND	.118
Fe	12.1	ND	1.76
Hg	.18	ND	.0181
K	293	.90	47.7
Mg	165.7	1.35	21.44
Mo	ND	ND	ND
Mn	3.76	ND	.485
Na			
Pb	1.41	ND	.18
Sb	.94	ND	.15
Si	23.8	2.6	10.9
Sr	660	ND	104.6
Ti	ND	ND	ND
W	ND	ND	ND
Zn	2.12	.112	.555
Zr	ND	ND	ND

* All values expressed in mg/l except pH in units and conductivity in $\mu\text{mho/cm}$.

Water Quality Sp Study No. 24-0586-77, 2-10 Aug 76

TABLE 6. ANALYTICAL RESULTS FOR INDUSTRIAL WASTE SUMP SEDIMENTS

Parameter		Sump Samples											Average	
		G05	G06'	G07	G08	G09	G10	G11	G12	G14	GP1	High		Low
Moisture	Percent	99.7	91.8				97.8	98.2	96.5		99.5	99.7	91.8	97.25
Solids	Percent	.3	8.2				2.2	1.8	3.5		0.5	8.2	.3	2.75
Volatile Solids	Percent	24	12				28	44	39		42	44	12	31.5
After Drying														
TP	mg/kg	555	964				188	200	2750		990	2750	188	94.1
Ca	mg/kg		1151				1440	6998	7050		3950	7050	1151	4118
Cd	mg/kg		11.4				4.3	14.2	82.7		21.8	82.7	4.3	26.9
Cu	mg/kg		415				27	121	385		440	440	27	278
Fe	mg/kg		268				36	277	550		375	550	36	301
Hg	mg/kg		ND				ND	ND	ND		ND	ND	ND	ND
K	mg/kg		1131				81	2592	1250		162	2592	81	1043
Mg	mg/kg		725				99250	9072	2750		5250	99250	725	23409
Mn	mg/kg		1.9				1.4	2.7	28.6		2.2	28.6	1.4	7.4
Pb	mg/kg		466				26	1016	2270		945	2270	26	945
Sb	mg/kg		108				ND	27	34		48	108	ND	43
Sr	mg/kg		2401				98	7	5		ND	2401	5	502
Zn	mg/kg		875				682	596	3600		965	3600	596	1344

Water Quality Sp Study No. 24-0586-77, 2-10 Aug 76

TABLE 7. DRAINAGE FROM BURNING GROUND AND POT CLEANUP AREA

Parameter*	Sample P-2 Burning Ground	Sample 28 Pot Cleanup Area
pH	7.5	2.6
Alkalinity as CaCO ₃	111	0
Acidity as CaCO ₃	11	176
Conductivity	366	1332
TS	284	368
TDS	268	84
TSS	16	234
VSS	14	232
COD	26	60
TOC	10	6
Oil & Grease		
Phenols		ND
NH ₃ -N	.06	ND
TKN	.40	.67
NO ₂ /NO ₃ -N	.49	ND
TP	ND	.18
Cl	30	165
F	.16	ND
SO ₄	34	8
Al	ND	ND
B	.12	ND
Ba	1.87	.88
Ca	13.0	1.9
Cd	ND	.006
Co	ND	ND
Cu	ND	ND
Cr	.026	ND
Fe	1.06	1.46
Hg	.00023	ND
K	5.74	.90
Mg	23.0	.76
Mn	ND	ND
Mn	.032	.077
Pb	ND	ND
Sb	ND	ND
Si	8.0	2.6
Sr	.890	ND
Ti	ND	ND
W	ND	ND
Zn	.149	.255
Zr	ND	ND

* All values expressed in mg/l except pH in units and conductivity in $\mu\text{mho/cm}$.

070030

Water Quality Sp Study No. 24-0586-77, 2-10 Aug 76

TABLE 8. ANALYTICAL RESULTS OF INDUSTRIAL WASTE POND SUPERNATANTS

Parameter *	15	Sample 16	17	Average
pH	4.0	4.1	4.1	4.1
Alkalinity	5	6	5	5
Acidity	17	19	20	19
Conductivity	2886	2997	2886	2923
TS	2738	2724	2738	2733
TDS	2728	2710	2696	2711
TSS	10	14	42	22
VSS	10	10	11	10
COD	49	41	45	45
TOC	15	19	20	18
Oil & Grease	1.3	ND	1.8	1.0
Phenols	.20	.22	.22	.22
NH ₃ -N	6.5	6.4	6.2	6.4
TKN	7.9	8.2	7.9	8.0
NO ₂ /NO ₃ -N	2.6	1.9	1.9	2.1
TP	.09	.08	.08	.08
Cl	775	890	785	817
F	.11	.11	.11	.11
SO ₄	20	20	30	23
Al	ND	ND	ND	ND
B	.19	.30	.18	.22
Ba	20.7	19.5	20.3	20.2
Ca	17.4	16.7	16.8	17.0
Cd	.010	.010	.012	.011
Co	ND	ND	ND	ND
Cu	.031	.032	ND	.021
Cr	ND	ND	ND	ND
Fe	.36	.77	.40	.51
Hg	.0002	ND	.00023	.00014
K	20.1	21.1	22.1	21.1
Mg	142.6	137.4	140.7	140.2
Mo	ND	ND	ND	ND
Mn	.145	.149	.144	.145
Pb	ND	.27	ND	.09
Sb	ND	.78	ND	.26
Si	ND	ND	ND	ND
Sr	4.49	4.45	4.58	4.51
Ti	ND	ND	ND	ND
W	ND	ND	ND	ND
Zn	.036	.035	.067	.046
Zr	ND	ND	ND	ND

* All values expressed in mg/l except pH in units and conductivity in $\mu\text{mho/cm}$.

Water Quality Sp Study No. 24-0586-77, 2-10 Aug 76

TABLE 9. ANALYTICAL RESULTS OF INDUSTRIAL WASTE POND SEDIMENTS

Parameter	Units	Sample					Average
		G-18	G-19	G-20	G-21	High	Low
Moisture	Percent	96.4	90.9	95.9	68.6	96.4	68.6
Solids	Percent	3.6	9.1	4.1	31.4	31.4	3.6
Volatiles Solids after drying	Percent						
TP	mg/kg	10	18	34	15	34	10
Ca	mg/kg	291	212	562	1607	1607	212
Cd	mg/kg	150	250	1709	457	1709	150
Cu	mg/kg	2.0	2.4	17.8	8.8	17.8	2.0
Fe	mg/kg	250	411	990	3650	3650	250
Hg	mg/kg	373	475	450	150	475	150
K	mg/kg	ND	ND	ND	ND	ND	ND
Mg	mg/kg	3153	3506	3392	1042	3506	1042
Mn	mg/kg	3253	4007	12062	122757	122757	3253
Pb	mg/kg	1.0	1.4	28.3	14.4	28.3	1.0
Sb	mg/kg	156	239	1593	1149	1593	156
Sr	mg/kg	32	36	65	40	65	32
Zn	mg/kg	ND	ND	37	19	37	ND
	mg/kg	168	213	1442	1845	1845	168

Water Quality Study No. 24-0586-77, 2-10 Aug 76

TABLE 10. CHARACTERIZATION OF RECEIVING WATERS

Parameter	North Bayou 27	P-4	Central Bayou 25	Harrison Bayou 24	Bayou 26	Caddo Lake 23	Raw Water 22	Tap Water P-3	High	Low	Average
pH	3.3	6.3	6.6	6.9	3.1	6.7	6.5	6.8			
Alkalinity	0	12	32	49	0	30	20	22	49	0	11
Acidity CaCO_3	41	9	12	11	69	9	15	10	69	9	33
Conductivity	710	155	322	233	699	122	133	211	710	155	472
TS	294	186	272	174	262	112	122	196	294	174	254
TDS	266	159	252	139	230	104	116	183	266	159	227
TSS	26	29	20	35	32	8	6	13	32	20	27
VSS	10	27	14	35	12	7	6	6	27	10	16
OD	25	32	42	28	46	22	21	12	46	25	37
TOC	10	10	14	13	15	8	10		15	10	12
Oil & Grease				4.9							4.9
Phenols	ND		ND		ND				ND	ND	ND
$\text{NH}_3\text{-N}$	.19	.06	ND	.11	ND	.13	.08		.19	ND	.06
TKN	.57	.50	ND	.78	ND	.47	.42	.11	.78	ND	.57
$\text{NO}_2/\text{NO}_3\text{-N}$	.52	ND	ND	ND	ND	ND	ND	ND	.52	ND	.13
TP	.67	.14	ND	ND	.17	ND	ND	.92	.67	ND	.24
Cl	125	35	50	29	120	21	30	25	125	35	82
F	.11	ND	.12	ND	ND	6	ND	ND	.12	ND	.06
SO_4	60	30	26	32	15		19	42	60	15	33
S											
Al	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Fe	.12	ND	.05	ND	ND	ND	ND	ND	.12	ND	.04
Mn	.38	.88	.12	.74	.40	.21	.44	ND	.88	ND	.44
Cu	18.5	10.1	ND	16.2	10.7	6.9	5.9		18.5	ND	9.8
Co	.006	ND	ND	.006	.006	.005	.009		.006	ND	.003
Zn	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Cr	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
Hg	.75	2.21	ND	2.12	4.60	.40	2.30		4.60	ND	1.89
Pb	.00065	ND	ND	ND	ND	ND	ND		.00065	ND	.00016
K	4.25	2.51	ND	3.57	3.86	1.90	3.55		4.25	ND	2.66
Mg	4.43	2.79	.11	9.48	5.46	1.84	2.58		5.46	.11	3.20
Mo	ND	ND	ND	ND	ND	ND	ND		ND	ND	ND
Mn	.079	.229	ND	1.26	1.13	ND	.149		.229	ND	.358
Na											
Pb	ND	ND	ND	ND	ND	ND	ND		ND	ND	ND
Sb	ND	ND	ND	ND	ND	ND	ND		ND	ND	ND
Si	16.1	13.5	12.0	7.5	9.2	3.2	13.9		16.1	9.2	12.7
Sr	.209	.410	.462	.361	.179	ND	.122		.462	.179	.320
Ti	ND	ND	ND	ND	ND	ND	ND		ND	ND	ND
W	ND	ND	ND	ND	ND	ND	ND		ND	ND	ND
Zn	.257	.482	ND	.332	.173	ND	.091		.482	ND	.228
Zr	ND	ND	ND	ND	ND	ND	ND		ND	ND	ND

All values expressed in mg/l except pH in units and conductivity in $\mu\text{mhos/cm}$.